



General Inspection – Fall

- 1. Check oil level. Inspect for leaks.
 Replace Engine Lubricating oil and filter, per manufacturers' specifications.
- N/A / 2. Check coolant level. Inspect for leaks.
- 3. Check carburetor, coolant or block heaters, plug in.
- 4. Inspect for nesting and put mouse bait in housing.
- 5. Inspect battery _____ DC voltage.
- 6. Inspect external wiring for wear, tension or other.
- 7. Manually run generator.
- N/A / 8. Test run and check voltage. _____ Volts A/C and frequency _____ HZ.
- 9. Battery required replacement; replaced today. If battery was replaced, you will be invoiced separately.

Hours on Meter: _____

Date Work Performed: _____

Technician: *Dave Carr*

Thank you for choosing Vermont Generator Systems. Your generator has been serviced and is in proper working order. I hope you enjoy the fall foliage and have a wonderful holiday season!

Notes: _____

