



Preventative Maintenance Report - Spring

- 1. Replace spark plugs per manufacturer's specifications.
- 2. Replace Engine Lubricating oil and filter, per manufacturers' specifications.
- N/A 3. Check radiator / cooling system and antifreeze. Replace lost coolant when doing annual inspection, up to 10% of system volume for standard size systems with unit mounted radiators, using Ethylene Glycol. Other size radiator systems or types of antifreeze will be invoiced separately.
- 4. Check air filter and crankcase breather. Replace air filter if required.
- 5. Check warning lights.
- 6. Check starter operation.
- 7. Check and lubricate governor. Adjust if required.
- 8. Check exhaust system.
- 9. Check fuel lines and hoses for pliability and leaks.
- N/A 10. Check fan and governor belts for wear and tension. (Liquid cooled generators only.)
- 11. Check engine block heater, carburetor heater or thermostat.
- 12. Check, clean and service battery. _____ DC Volts Battery Voltage Added Water.
- 13. Check battery charger. Adjust as required.
- 14. Check external wires for wear and tension.
- 15. Check logics and connections. Adjust as required.
- 16. Check Exerciser. Adjust as required.
- 17. Inspect unit for animal nesting and clean as required.
- 18. Test run and check voltage. _____ Volts A/C and Frequency _____ Hz.

Hours on Meter: _____

Date Work Performed: _____

Technician: *Dave Carr*

Thank you for choosing Vermont Generator Systems. Your generator has been serviced and is in proper working order. Have a great summer!

NOTES: _____

